

Manufacturer: ETI Elektroelement d.d.

Address: Obrezija 5

1411 Izlake, SLOVENIA

Product: CH Low-voltage Fuses, Fuse Links

Size CH14, gG, without striker pin

2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A/690Va.c., 32A, 40A, 50A/500Va.c.

Size CH14, gG, with striker pin

2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A, 32A, 40A/500Va.c., 50A/400Va.c.

Size CH14, aM, without striker pin

2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A/690Va.c., 32A, 40A, 50A/500Va.c.

Size CH14, aM, with striker pin

2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A, 25A, 32A, 40A/500Va.c., 50A/400Va.c.

The designated product confirm to the provision of the following European directives:

2006/95/EC

Directive of the European Parliament and of the Council of 12 December 2006 on the harmonisation of the laws of Member States relating to electrical equipment designed for use within certain voltage limits.

2011/65/EU

Directive of the European Parliament and of the Council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (recast).

Our products are constructed and manufactured based on our Quality Management System (according to DIN EN ISO 9001) in correspondence to the following standards:

The type test of listed product was made under the requirements of the following standards and with that fulfilled the requirements of European directive and following IEC and EN standards:

Standards: IEC 60269-1 Ed. 4.0 : 2006-11, IEC 60269-1 Ed. 4.1 : 2009-07,

IEC 60269-2 Ed. 5.0: 2010-03

DIN EN 60269-1: 2010-03, VDE 0636-1: 2010-03,

DIN VDE 0636-2; VDE0636-2: 2011-09

Licence No.: CB certificate MEEI Nr.HU 214

Test report Nr. V-02586/A, B,C,D,E, F,G,H,I

Marking with CE: On the product

On the packaging

Place and date: Izlake, 09.12..2013

Manufacturer representative signature and stamp: Viktor Martinčič, univ.dipl.ing