



## **CE - DECLARATION OF CONFORMITY**

**Product:** *Residual Current Circuit Breaker with  
integral overcurrent protection*

**Manufacturer:** *ETI Elektroelement d.d.  
1411 Izlake, Obrezija 5*

**SLOVENIA**

**Model/Type:** *KZS-2M*  
**Rated voltage/Rated currents:** *B 6 – 40  
C 6 - 40  
 $I_{\Delta n} = 0,03, 0,3 \text{ A}$   
 $U_n = 230 \text{ V}$   
Tip: A, AC*

*Products to which this declaration relates are in conformity with the provisions of the following  
EC Directive(s):*

<b>2006/95/EC</b>	<b>Low Voltage Directive</b>
<b>2004/108/EC</b>	<b>EMC Directive</b>

*And with the following standards:*

**IEC 61009-1 (2006)**  
**EN 61009-1 (2004)**

*Test report/Issued by:*

**2.03.00938.1.0/KZS2MCB/CCA**  
**ÖFPZ Arsenal, Dunaj**

*Year of CE marking:*

**2005**

*Place and date:* *Izlake, 23.08.2009*

*Matija Strehar, R&D manager*

ELEKTROELEMENT d.d.  
IZLAKE  
21  
**ETI**  
*Matija Strehar*